

NEXT-100 Pressure Vessel, May 7, 2012

D. Shuman¹, S. Carcel², A. Martinez²

¹Lawrence Berkeley National Laboratory(LBNL), ² Instituto Physica de Corpuscular (IFIC)

May 8, 2012

Table of Contents

1 NEXT-100 Pressure Vessel

- Progress to Date
- Parameters
- NEXT100 Pressure Vessel Parameters
- Detector Overall Cross Section
- ICS(barrel) Calibration Source Collimators
- Vessel, as delivered (nozzle extensions to be added in later)
- Vessel Supports
- Gas Vent and Pressure Relief
- Head and Energy Plane Servicing Scheme
- Field Cage Servicing Scheme
- Movesa
- Next Steps

Vessel Design simplified, Material chosen (S.S., 316Ti alloy).

- Torispheric heads identical - 4 nozzles each - extra capacity
- Head nozzles shortened - extensions will be used as needed
- Nozzle extensions and cover plates contain O-ring grooves and pumpout ports
- 316Ti (EN1.4571) - best radiopurity (200 mBq/kg), popular alloy, plate only (ASME, div 1 only)


Manufacturer chosen - Movesa , Madrid


- Site visit Fall 2011 - one other mfr. visited
- Capable and versatile mfr. - boilers, reactors for food and pharmaceutical, turnkey processing systems
- Separate facilities for stainless steel vs carbon steel
- Convenient for frequent visits during fabrication

User Design Specification Completed (ASME)


- Specifies all vessel requirements and operating conditions
- Now goes to Mfr. and Certifying Authority for review and approval
- Mfr. will recalculate - final design must be agreed upon
- Head thickness may meet EU code, but not ASME


Parameter	qty	units
Active Volume Radius	53	cm
Active Volume Length	130	cm
Maximum Operating Pressure (MOP) (differential)	14.0	bar
Maximum Allowable Working pressure (MAWP) (differential)	15.4	bar
Minimum Allowable Pressure (differential)	1.5	bar
Inner diameter	136	cm
Outer Diameter, Vessel	138	cm
Outer Diameter, Flanges	148	cm
Length, inside inner shielding	2.26	m
Length, end to end, axial	2.48	m
Vessel Material, Austenitic Stainless Steel, Alloy	316Ti	
Cylindrical Vessel Wall thickness	10	mm
Torispheric Head Wall thickness	10.5	mm
Flange thickness, head to vessel (each)	4.15	cm
Bolt Diameter (Inconel 718), head to vessel flanges	16	mm
Bolt length, head to vessel flanges	11	cm
Number of Bolts, each head to vessel flange	132	
Mass, Vessel and both heads	1200	kg
Mass, Internal copper shielding, total (12 cm)	10000	kg
Total Detector and Vessel Weight	12000	kg






Double O-ring leak check port moved to heads, (no alignment issue)







TOP


2X COVER PLATE, DWS, DWS 28K395A

MAIN CYLINDRICAL VESSEL, DWS 28K390A

500X WASHER, HEAVY, NARROW, 389H 02, 1/2 INCH, 7/8
 500X NUT, HEAVY, 7/8-1/2 INCH, 7/8, SILVER PLATE
 264X STUD, 7/8-1/2, DWS 28K390

2X TORISPHERIC HEAD, DWS 28K390A


2X COVER PLATE, DWS, DWS 28K395A



FRONT

GENERAL NOTES


1. THIS DRAWING IS A PART OF NEXT-100-FYI USER DESIGN SPECIFICATION
2. THIS DRAWING IS PRELIMINARY, AND SETS FORTH BOTH REQUIRED DIMENSIONS, AND PRELIMINARY DIMENSIONS TO BE VIEWED BY MANUFACTURER.
3. ALL PARTS TO BE FABRICATED, INSPECTED AND TESTED IN ACCORDANCE WITH JOINT SELLER AND PRESSURE VESSEL CODE SECTION VIII, DIV. 1 OR EQUIVALENT.
4. ADDITIONAL REQUIREMENTS APPLY CONCERNING CLEANING, PREPARATION, INSPECTION, WELDING, HEAT TREATING.
5. VESSEL IS FOR BOTH HIGH PRESSURE (154 BAR) AND HIGH VACUUM (10⁻⁶ TORR) SERVICE.
6. VESSEL SHALL BE DELIVERED IN CLEAN CONDITION, SERVICEABLE FOR HIGH VACUUM SERVICE.




DATE	2012-05-08	BY	ERIN OLLIVIO
DESIGNED BY	ERIN OLLIVIO	CHECKED BY	ERIN OLLIVIO
APPROVED BY	ERIN OLLIVIO	DATE	2012-05-08
PROJECT	NEXT-100	PROJECT	NEXT-100
SCALE	1:1	SCALE	1:1
REVISION	1	REVISION	1
REVISION	2	REVISION	2
REVISION	3	REVISION	3
REVISION	4	REVISION	4
REVISION	5	REVISION	5
REVISION	6	REVISION	6
REVISION	7	REVISION	7
REVISION	8	REVISION	8
REVISION	9	REVISION	9
REVISION	10	REVISION	10
REVISION	11	REVISION	11
REVISION	12	REVISION	12
REVISION	13	REVISION	13
REVISION	14	REVISION	14
REVISION	15	REVISION	15
REVISION	16	REVISION	16
REVISION	17	REVISION	17
REVISION	18	REVISION	18
REVISION	19	REVISION	19
REVISION	20	REVISION	20
REVISION	21	REVISION	21
REVISION	22	REVISION	22
REVISION	23	REVISION	23
REVISION	24	REVISION	24
REVISION	25	REVISION	25
REVISION	26	REVISION	26
REVISION	27	REVISION	27
REVISION	28	REVISION	28
REVISION	29	REVISION	29
REVISION	30	REVISION	30
REVISION	31	REVISION	31
REVISION	32	REVISION	32
REVISION	33	REVISION	33
REVISION	34	REVISION	34
REVISION	35	REVISION	35
REVISION	36	REVISION	36
REVISION	37	REVISION	37
REVISION	38	REVISION	38
REVISION	39	REVISION	39
REVISION	40	REVISION	40
REVISION	41	REVISION	41
REVISION	42	REVISION	42
REVISION	43	REVISION	43
REVISION	44	REVISION	44
REVISION	45	REVISION	45
REVISION	46	REVISION	46
REVISION	47	REVISION	47
REVISION	48	REVISION	48
REVISION	49	REVISION	49
REVISION	50	REVISION	50
REVISION	51	REVISION	51
REVISION	52	REVISION	52
REVISION	53	REVISION	53
REVISION	54	REVISION	54
REVISION	55	REVISION	55
REVISION	56	REVISION	56
REVISION	57	REVISION	57
REVISION	58	REVISION	58
REVISION	59	REVISION	59
REVISION	60	REVISION	60
REVISION	61	REVISION	61
REVISION	62	REVISION	62
REVISION	63	REVISION	63
REVISION	64	REVISION	64
REVISION	65	REVISION	65
REVISION	66	REVISION	66
REVISION	67	REVISION	67
REVISION	68	REVISION	68
REVISION	69	REVISION	69
REVISION	70	REVISION	70
REVISION	71	REVISION	71
REVISION	72	REVISION	72
REVISION	73	REVISION	73
REVISION	74	REVISION	74
REVISION	75	REVISION	75
REVISION	76	REVISION	76
REVISION	77	REVISION	77
REVISION	78	REVISION	78
REVISION	79	REVISION	79
REVISION	80	REVISION	80
REVISION	81	REVISION	81
REVISION	82	REVISION	82
REVISION	83	REVISION	83
REVISION	84	REVISION	84
REVISION	85	REVISION	85
REVISION	86	REVISION	86
REVISION	87	REVISION	87
REVISION	88	REVISION	88
REVISION	89	REVISION	89
REVISION	90	REVISION	90
REVISION	91	REVISION	91
REVISION	92	REVISION	92
REVISION	93	REVISION	93
REVISION	94	REVISION	94
REVISION	95	REVISION	95
REVISION	96	REVISION	96
REVISION	97	REVISION	97
REVISION	98	REVISION	98
REVISION	99	REVISION	99
REVISION	100	REVISION	100


Is there significant stress and deflection from Copper shielding bars?


Load= 12000kg total both flanges





Deflection (0.1mm) and stress (2.E7 Pa) are minimal (14.E7 Pa max allowable)

















Straight-through fast vent valve (Danfoss) for refrigerants, inert gas



- solenoid actuated for anomalous pressure drop/rise, vacuum loss?
- pilot-operated - pressure on piston backside seals tighter at H.P
- pop-action - poppet opens fully upon action
- concern about permation through gaskets - make our own?

6 strut "hexapod" kinematic support fixture





Reactor Vessels for Food and Pharmaceutical Production



Manifolds for Turnkey Processing Systems



Large Vessel Capability



- Consult with Mfr. on Design
 - Flange, head dimensions achievable with mtl? calcs agree?
 - Get UDS certified
 - check: Helicoflex compatibility, seismic transverse load capacity
 - Review Mfr's construction plan, identify steps of inspection, cleaning, joint prep
 - Can they achieve the specified tolerances? heat treat cycles?
- Proceed with design of remainder of system
 - valve(s) specification
 - recovery vessel (1 or more vessels?, location? bakeable?)
 - expansion joint design - what is max pressure? max force on nozzle?
 - start control system specification- what are appropriate fast vent triggers
 - cold trap efficiency? Fast VAT valve appropriate